

18 September 2020

18045-BOW Bowmar Elementary / Report Number 014

201 Park Court, Suite B Ridgeland, MS 39157 P 601.790.9432 F 888.281.0547	Contract	Paul Jackson & Son
	Date / Time	16 September 2020 / 3:30 PM
	Weather / Temp	Partly cloudy / 86 ° F
	Est % Complete	35%
One Jackson Place, Suite 250 188 East Capitol Street Jackson, MS 39201-2100 P 601.352.5411 F 601.352.5362	Sched Conformance	+/- 00 days
	Work in Progress	Base Installation
	Present at Site	Jimmy White, Paul Jackson & Son Paul Purser, DBA
161 Lameuse Street, Suite 201 Biloxi, MS 39530 P 228.374.1409 F 228.374.1414	Observations	I arrived on site as night-shift workers were arriving. Some day-shift workers were completing base at the Auditorium. Flooring in the auditorium appears complete. Cuts at Door jambs and steel columns are tight and appear to be of good workmanship. At the rear yard where building pad work is ongoing, footings have been dug and rebar work has begun.
	Items to Verify	None
	Action Required	None
	Report By:	

Paul Purser, AIA, LEED AP
Dale | Bailey, an Association

cc: James Brock / Jimmy White (PJS)
Chad Shealy / Shaquita Burke / Bill Sanderford (VWSD)
Gary Bailey / Jason Stewart / Mark Pipper (BPM)
Russ Blount / Travis Altsman / Abigail Raper / Candy Failor (DBA)
Tom Schaeffer / Will Grigg (M)
Kevin Starks / Jason Kackley / Al Guynes (GSK)
Chris Green / Larry Scott (TPS)



Figure 1 – Auditorium VCT Installed



Figure 2 – Auditorium VCT Installed



Figure 3 – Auditorium VCT Installed & Walls Painted



Figure 4 – Auditorium VCT Installed & Walls Painted



Figure 5 – Auditorium VCT Installed & Walls Painted



Figure 6 – Cuts at Door Jambs Look are Acceptable



Figure 7 – Base Installing at Auditorium is nearing Completion



Figure 8 – Footing Excavation at Rear Addition



Figure 9 – Footing Excavation at Rear Addition



Figure 10 – Footing Excavation at Rear Addition



Figure 11 – Footing Excavation at Rear Addition



Figure 12 – Footing Excavation at Rear Addition



Figure 13 – Rebar Prepped for Installation at Footing Excavations



Figure 14 – Rebar Prepped for Installation at Footing Excavations



Figure 15 – Below Slab Drainage Prepped for Concrete Install



Figure 16 – Rear Addition Building Pad