

## Architect's Field Report

201 Park Court, Suite B  
Ridgeland, MS 39157  
P 601.790.9432  
F 888.281.0547

30 September 2021

18056-Warren Central Junior High School / Report Number 027

One Jackson Place, Suite 250  
188 East Capitol Street  
Jackson, MS 39201-2100  
P 601.352.5411  
F 601.352.5362

Contract Paul Jackson & Son  
Date / Time 30 September 2021 / 1:00 PM  
Weather / Temp Overcast / 80 ° F  
Est % Complete 99%  
Sched Conformance + 90 days  
Work in Progress None

161 Lameuse Street, Suite 201  
Biloxi, MS 39530  
P 228.374.1409  
F 228.374.1414

Present at Site Paul Purser, DBA

Observations Work is nearing completion here. The final handrail has been partially installed but requires a little work as well as paint. Paint at all steel at the exterior is needed.

Items to Verify None

Action Required None

Report By:

Paul Purser, AIA, LEED AP  
Dale | Bailey, an Association

cc: Austin Stults / Tim Wilson / Kipp Ready (PJS)  
Chad Shealy / Christi Kilroy (VWSD)  
Gary Bailey / Jason Stewart / Mark Pipper (BPM)  
Russ Blount / Candy Failor (DBA)  
Brandon McKay / Austin Newell (WGK)  
Jason Kackley / Al Guynes (GSK)  
Chris Green / Larry Scott (TPS)  
Tom Schaeffer / Tad Hoffpaur (SDG)



Figure 1 – Handrail Partially Installed



Figure 2 – Straighten handrail to lengths are parallel



Figure 3 – Field repairs needed at handrails



Figure 4 – Final coating needed at steel